



Size	1/2"	3/4"	1"	1 1/4"	1 1/2"	2"
A	2 3/4"	3"	3 3/4"	4 7/16"	4 15/16"	6 1/8"
B	2 1/4"	2 9/16"	2 3/4"	3 5/8"	3 7/8"	5 1/8"
C	1/4"	3/8"	3/8"	3/4"	3/4"	1"
Wt	.75	1.38	2.13	3.13	4.5	7

#### NOTES:

- BODY AND CAP SHALL BE BRONZE ASTM B62; SCREEN SHALL BE 20 MESH STAINLESS STEEL; GASKET SHALL BE NON-ASBESTOS; ENDS SHALL BE THREADED ANSI/ASME B1.20.1
- WORKING PRESSURE SHALL BE NON-SHOCK, 200 PSI @ 150 DEGREES
- REFER TO CITY STANDARD DETAIL LSD-14 FOR ALL MATERIALS

			<b>CITY OF FREMONT</b> STANDARD DETAILS <b>CITY STANDARD</b> <b>IRRIGATION WYE STRAINER</b>			DATE APPROVED BY CITY COUNCIL 04/11/06	
						RESOLUTION NO. 2006-31	
						 CITY ENGINEER	
NO.      REVISED      DATE REVISIONS							
FILE NO. LSD-26.DWG		SCALE 1" = 1'-0"	DRAWN AK/MM/PM	CHECKED RER	DATE NOV. 2005	DWG NO. LSD-26	26 of 27